


# CL 6048 with 3 Pumps Installed




## Parts List\*

Qty	p/n	Description
3	118	3/4" Close Nipple
3	198	3/4" Ball valve
3	224	3/4" Isolation Flange Kits
2	274	3/4" Black 90° Street Elbow
3	296	3/4" Swing Check Valve
2	388	1-1/4" x 3/4" Bushing
1	534	3/4" x 7" Nipple
2	536	3/4" x 7" Brass Nipple
3	556	Power Supply Cord, 32"
1	582	6 Outlet Converter
6	1330	3/4" x 1" MPT to PEX
4	3042	1/2" x 1/8" Bushing
2	5367	3/4" Brass Coupling
4	6054	Temperature Gauge
1	6593	Grounding Rod Kit
2	6764	3/4" x 3/4" x 1/2" Offset Tee
3	5800004	007 Pump


\*Parts and accessories sold separately.

## Return Side View

For illustration purposes only.



\*\*For 1-1/4" lines use p/n 5871.  
Central Boiler recommends installing swing check valves on the return lines to eliminate reverse flow.



## NOTE

Grounding Rod Kit (p/n 6593) must be installed with every furnace.

